

ADDENDUM NO. 2
BLUE GRASS AIRPORT
ADMINISTRATIVE OFFICES AND BOARD ROOM RENOVATION
DATE OF ISSUE: SEPTEMBER 6, 2011

Information in this document contains written questions received from interested proposers and answers from BGA staff.

Questions and Answers

Q1. If furniture suppliers do not participate on a team, will they be excluded from bidding opportunities related to the project?

A1. The project is for planning and design only. Supply, installation and construction bids will be open to all bidders at some point in the future.

Q2. The contract included in Addendum No. 1 did not include specific amounts for insurance. What level of insurance will be required for the project?

A2. General Liability - \$1,000,000 per occurrence, \$2,000,000 aggregate. Automobile - \$2,000,000. Umbrella - \$2,000,000 per occurrence, \$2,000,000 aggregate. Workers Compensation - \$1,000,000. Professional Liability - \$1,000,000 per claim, \$1,000,000 aggregate.

Q3. Are there to be any changes to the HVAC in the Media Room?

A3. The existing heat pumps are functional and will not be addressed in this project.

Q4. What HVAC systems serve the Media Room and other project areas? Are these systems the original equipment?

A4. Most of the areas in the project are served by heat pumps. Some of the pumps are original and some have been replaced over time.

Q5. Is the existing fire alarm system an addressable or non-addressable type system?

A5. The head end equipment is addressable, though some of the devices may need to be upgraded to addressable devices during the renovation. Where upgrades are necessary, the airport will work with its fire alarm contractor.